# Appendix B

Certified Validation Report Template, Part A: Provided by Validator

#### **Audit Information:**

Water Supplier Name: Scotts Valley Water District PWS ID:4410013

System Type: Potable

Audit Period: Calendar 2018

Utility Representation: David McNair (Operations Manager)

Validation Date:9/19/2019

Call Time:12:00PM

**Sufficient Supporting Documents Provided: Yes** 

### **Validation Findings & Confirmation Statement:**

## **Key Audit Metrics:**

Data Validity Score:60 Data Validity Band (Level):Band III (51-70)

ILI: 0.76

Real Loss: 17.88 gallons/connection/day

Apparent Loss: 2.76 gallons/connection/day

Non-revenue water as percent of cost of operating system: 1.6%

#### Certification Statement by Validator:

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit.  $\Box$ 

If not, rejected recommendations are included here.

#### Validator Information:

Water Audit Validator: Tanmay Thakur from Nobel Systems. Qualifications: Water Audit Validator Certificate issued by the CA- NV Section of the **AWWA** 

**Executive Name (Print)** 

# Certified Validation Report Template, Part B: Provided by Utility

Water Supplier Name:	Water Supplier ID Number:	Water Audit Period:
Water Audit & Water Loss Improvement Steps:		
Utility to provide steps taken in preceding year water audit:	to increase data validity, reduce real loss and ap	parent loss as informed by the annual validated
Certification Statement by Utility Executive:		
Code Section 10608.34 and has been prepared i	ments of California Code of Regulations Title 23 in accordance with the method adopted by the A rograms, Manual M36, Fourth Edition and in the	American Water Works Association, as contained

Signature

Date

**Executive Position**